

Memorandum



Henault
99
140.2
747

DATE : June 23, 1978
TO : Ivan Holbrook
FROM : Pete Henault
SUBJECT : PCB Identification and Disposal

See log p
1053

We have reviewed the rough draft of proposed instructions on PCB identification and disposal. The draft appears to be a thorough response to the EPA requirements.

I would request that on page 2, in Section 1 on Recording, that the Manager of Substations be required to notify the Environmental Affairs Office within 3 working days of any damage to equipment which results in the release of PCB's outside a contained space, and immediately of any release of PCB's outside City Light facilities.

Thank you for the opportunity to review the proposed procedures.

RKW:ag

cc: Recchi	Bucknell
Youngs	Stretch
Thompson	Hunich
Jones	Jerochim
Naud	Cohn
Sleater	Eaton
Wheelock	Henault (3)
	File